

PUBLIC HEALTH ENGINEERING DEPARTMENT GOV. OF BIHAR

Water Quality Test Report

P.H.Division, Sherghati


1. District- Gaya
2. Block - Manpur
3. Location Detail - DIGNANI GLOBAL SCHOOL ,NI-82 Budhgera,Kalya,Manpur ,Bihar- 823003
4. Type Of Source - Deep Tubewell

Sampling Date:- 31-05-2025

Testing Date:- 02-06-2025

Sl no	PARAMETERS	Desirable Limit (value in mg/l)	Permissible limit in Absence of	Water testing result (In mg/l)	Remarks
1	Turbidity	1.0 NTU	5.0 NTU	0.13	Analysed sample of water conforms to Indian standard limit (IS 10500:2012)
2	pH	6.5-8.5	No relaxation	7.43	
3	Conductivity	-	-	421	
4	Total Hardness	200	600	180	
5	Total Alkalinity	200	600	220	
6	Calcium	75	200	48	
7	Magnesium	30	100	14.58	
8	Chloride	250	1000	30	
9	TDS	500	2000	273	
10	T.Coliform	Absent	Absent	Negative	

Note:- [i] Drinking water specification second Revision- IS:10500:2012, [ii] BDL means Below Detection limit, [iii] NR means no relaxation.


 09/06/2025
 Signature of the CHEMIST
 PH Division Sherghati

SAFE DRINKING WATERNO 200Date: 14/6/2025

It is certified that an Inspection team headed by UDAY CHAND RAM, (Name of Officers with designation) from ASSISTANT ENGINEER, PH SUB DIVISION, GAYA (Name of department/Office) inspected the DIGMANI GLOBAL SCHOOL, NH-82 BUDHGERE, KAIYA, MANPUR, BIHAR 823003 (Name & Address of the School) on 31.5.2025 and on the basis of Water Test Report (attached) bearing no. 15/2025 dated 02.6.2025 of (PHED Lab) certified that facilities for the students and members of staff of the institution. The campus as per the norms prescribed by the Central/State/U.T. Govt.

This certificate is valid till ONE YEAR.

Signature

Name

Designation

①
14/6/25
Assistant Engineer
P.H. SUB DIVISION, Gaya West
Name & Add. Of Department/ Office: P.H
SUB DIVISION, GAYA WEST, GAYA

To

DIGMANI GLOBAL SCHOOL,
NH-82 BUDHGERE, KAIYA,
MANPUR, BIHAR-823003

(Name & Address of the Institution)